

CERTIFICATE

Anbotek
Product Safety

CERTIFICATE

Of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AT58230SC000011

Report No.: 58230SC00001101

Page 2 of 2

Rating: IP65, Class I;
TP10KTLM:
Input: Max. 1000VDC, MPPT voltage range 250-850VDC, max. 2x17A;
Output: 400VAC/3~, 50Hz, 10000W, max.17A;

TP8KTL:
Input: Max. 1000VDC, MPPT voltage range 200-850VDC, max. 2x17A;
Output: 400VAC/3~, 50Hz, 8000W, max.15A;

TP6KTL:
Input: Max. 1000VDC, MPPT voltage range 200-850VDC, max. 2x17A;
Output: 400VAC/3~, 50Hz, 6000W, max.12A;

TP5KTL:
Input: Max. 1000VDC, MPPT voltage range 200-850VDC, max. 2x17A;
Output: 400VAC/3~, 50Hz, 5000W, max.10A;

TP4KTL:
Input: Max. 1000VDC, MPPT voltage range 200-850VDC, max. 2x17A;
Output: 400VAC/3~, 50Hz, 4000W, max.8A;

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.

Jul. 13, 2020

Date



Certified by

Terry Tian
Manager



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Anbotek (Guangzhou) Compliance Laboratory Limited

Room508, Building 2, No.232, Kezhu Road, Science City, Guangzhou Economic & Technology Development Area, Guangzhou, Guangdong, China

Tel: (86)20-82575737

[Http://www.anbotek.com](http://www.anbotek.com)

Email:service@anbotek.com